

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015783
DATE: 04/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Kleidco
CODE: 2909-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Kleidco Aluminum Solutions No: 14/1 34197 Bahceliever Istanbul, Turkiye	Series "ICON 70" Aluminum Casement Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1524mm(60") Vent: W-854mm(33.61") H-1463mm(57.59")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG90 914 x 1524 (36 x 60)-C Design Pressure: ± 4320 Pa (90 psf) Water Penetration Resistance Test Pressure: 580 Pa (12 psf)

Product Tested By: Farabaugh Engineering and Testing, Inc.
Report No: TN 118-19(1)
Expiration Date: April 30, 2027

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com