## NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI015786.01
04/18/2023
Structural
Artistic Doors
1992-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Artistic Doors & Windows Manufacturing	Series "1100" Mahogany
10 South Inman Avenue	Wood Triple Fixed Window
Avenel, New Jersey 07001	
	Configuration: OOO Glazing: IG-Ext-1/4" Annealed Glass/0.090" Kuraray SGP Interlayer/1/4" Annealed Glass/Int-3/16" Tempered Glass
	Frame: W-4775mm(188") H-2794mm(110")
	DLO: W-1486mm(58.50") H-2705mm(106.50")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +75/-75 Water Penetration Resistance Test Pressure: 540 Pa (11.28 psf) Large Missile Impact Rated
Product Tested By: Molimo, LLC	

Report No: 1 Expiration Date: A

Molimo, LLC 1996.14-106-11 **April 30, 2027** 

Sh!

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com