

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015791
DATE: 04/18/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Artistic Doors
CODE: 1992-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Artistic Doors & Windows Manufacturing 10 South Inman Avenue Avenel, New Jersey 07001	Series "8200" Mahogany Wood Glazed Inswing Double Side-Hinged Door Configuration: XX Glazing: IG-Ext-3/16" Annealed Glass/0.090" Kuraray SGP Interlayer/3/16" Annealed Glass/Int-3/16" Tempered Glass Frame: W-1956mm(77") H-3353mm(132") Panel: W-953mm(37.50") H-3277mm(129") DLO: W-775mm(30.50") H-3042mm(119.75")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +60/-60 Water Penetration Resistance Test Pressure: 440 Pa (9.20 psf) Large Missile Impact Rated

Product Tested By: Molimo, LLC
Report No: 1996.19-106-11
Expiration Date: April 30, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'Molimo'.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com