

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015793
DATE: 04/17/2023
CERTIFICATION PROGRAM: Fire
COMPANY: Form-Cove
CODE: 2880-1
EXPIRATION DATE: 04/30/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Form-Cove Enterprises, LLC 500 Frontage Road, Northeast Rio Rancho, NM 87124	20-Minute Fiberglass Fire Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2017) UL 10C (2016) CAN/ULC S104 (2015)	20 Minute-Neutral/Positive Pressure With Hose Stream Category B - Additional Edge-Sealing System Required

TEST REPORT
Intertek Test Report No: 103550846MID-003, G103550846 NAMI Waiver of Retest: W-2063

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com