

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015794  
**DATE:** 04/18/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Artistic Doors  
**CODE:** 1992-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Artistic Doors &amp; Windows Manufacturing</b> <b>10 South Inman Avenue</b> <b>Avenel, New Jersey 07001</b>	<b>Series "1100" Mahogany</b> <b>Wood Fixed Window</b>  Configuration: O Glazing: IG-Ext-1/4" Tempered Glass/Int- 3/16" Annealed Glass/0.090" Kuraray SGP Interlayer/3/16" Annealed Glass  Frame: W-1575mm(62") H-2794mm(110")  DLO: W-1486mm(58.50") H-2705mm(106.50")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: +70/-70</b> Water Penetration Resistance Test Pressure: 510 Pa (10.66 psf) <b>Large Missile Impact Rated</b>

Product Tested By: Molimo, LLC  
Report No: 2330.02-106-11/1996.13-106-11  
Expiration Date: April 30, 2027

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)