

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015795.05
DATE: 04/18/2023
CERTIFICATION PROGRAM: Mfg Hsg
COMPANY: Millwork Sales
CODE: 434-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Millwork Sales of Orlando 1925 Parks Oaks Avenue Orlando, FL 32808	Plastpro 3'0" x 6'8" Glazed Fiberglass In-Swing Side Hinged Door (w/Sidelites & Composite Jambs) Configuration: OXO Frame: W-1743mm(68.63") H-2083mm(82") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-537mm(21.13") H-1604mm(63.13") STP: Pos+2298 Pa (48 psf) Neg-2298 Pa (48 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95 Federal Manufactured Home Construction & Safety Standard 3280.405	Manufactured Housing-Passed Wind Zone II Design Wind Pressure Rating: +48/-48 psf

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01393402
Expiration Date: September 30, 2024

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

nami@namiinc.com

