

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015797
DATE: 04/24/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Crystal Pacific
CODE: 2018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Crystal Pacific Windows Corporation 1850 Atlantic Avenue Riverside, CA 92507	Series "Vista Plus" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1829mm(72") Sash: W-1791mm(70.50") H-1791mm(70.50") DLO: W-1664mm(65.50") H-1664mm(65.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class CW-PG30 1829 x 1829 (72 x 72)-FW Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: E6626.01-301-44
Expiration Date: April 30, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com