

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015798  
DATE: 04/24/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Crystal Pacific  
CODE: 2018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION   |
|---|---|
| <b>Crystal Pacific Windows Corporation</b><br><b>1850 Atlantic Avenue</b><br><b>Riverside, CA 92507</b> | <b>Series "Vista Plus"</b><br><b>Vinyl Single Hung Window</b><br><br>Configuration: O/X<br>Glazing: Insulating Glass (Annealed)<br>Frame: W-1194mm(47") H-2134mm(84")<br>Sash: W-1136mm(44.75") H-1049mm(41.31")<br>DLO: W-1054mm(41.50") H-968mm(38.13") |

| SPECIFICATION                          | PRODUCT RATING  |
|--|---|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> | <b>Class LC-PG30 1194 x 2134 (47 x 84)-H</b><br><b>Design Pressure: ±1440 Pa (±30 psf)</b><br>Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf) |

Product Tested By: Intertek, PLC  
Report No: E6625.01-301-44  
Expiration Date: April 30, 2027

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)