## **NOTICE OF PRODUCT CERTIFICATION**



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI015775.01	
05/16/2023	
Structural	
Quaker	
031-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DES	CRIPTION
Quaker Window Products		Series "W	<b>200"</b>
504 Highway 63 South		Aluminum Fren	ich Inswing
Freeburg, MO 65035		Side Hinge	d Door
		Configuratio Glazing: Insulating G	
	Frame:	W-1829mm(72")	H-2108mm(83")
	Panel:	W-884mm(34.81")	H-2032mm(80")
	DLO:	W-713mm(28.06")	H-1861mm(73.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG30 1829 x 2108 (72 x 83)-SHD
CSA A440S1-09	<b>Design Pressure:</b> ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)
	Canadian Infiltration/Exfiltration Level: A2

Product Tested By:	Intertek, LLC
Report No:	P6755.01-801-44
Expiration Date:	<b>January 31, 2027</b>

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Email: <u>nami@namiinc.com</u>