

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015783.01  
DATE: 05/08/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Kleidco  
CODE: 2909-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Kleidco Aluminum Solutions</b> <b>No: 14/1 34197 Bahceliever</b> <b>Istanbul, Turkiye</b>	<b>Series "ICON 70"</b> <b>Aluminum Casement Window</b> <b>(w/Non-Thermally Broken Frame)</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-914mm(36") H-1524mm(60") Vent: W-854mm(33.61") H-1463mm(57.59")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG75 914 x 1524 (36 x 60)-C</b> <b>Design Pressure: ±3591 Pa (75 psf)</b> Water Penetration Resistance Test Pressure: 580 Pa (12 psf)

Product Tested By: Farabaugh Engineering and Testing, Inc.  
Report No: TN 118-19(1)/W-2066  
Expiration Date: April 30, 2027

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)