

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015808  
**DATE:** 05/15/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Elegantview  
**CODE:** 2911-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Elegantview Windows</b> <b>4492 Commerce Circle SW</b> <b>Atlanta, Georgia 30336</b>	<b>Series "9200-DHS"</b> <b>Vinyl Horizontal Slider Window</b>  Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1600mm(63") H-1118mm(44") Sash: W-762mm(30") H-1016mm(40") DLO: W-673mm(26.50") H-927mm(36.50")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class R-PG35 1600 x 1118 (63 x 44)-HS</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: Intertek PLC  
Report No: L3580.02-901-44/L3579.01-901-44  
Expiration Date: **December 31, 2026**

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)