

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015812
DATE: 05/22/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "R45F" Aluminum Window Wall System Configuration: OOO/X/OO/XOO Glazing: Insulating Glass (Tempered) Frame: W-7630mm(300.38") H-3181mm(125.25") Panel: W-819mm(32.25") H-1486mm(58.5") DLO: W-1448mm(57") H-2978mm(117.25")

SPECIFICATION	PRODUCT RATING
ASTM E283/E283M-19 ASTM E330/E330M-14 ASTM E331-00(2016) ASTM E547-00(2016) AAMA 501.1-17	Design Pressure: ±1920 Pa (±40 psf) Static Water Penetration Resistance Test Pressure: 730 Pa (15.26 psf) Dynamic Water Penetration Resistance Test Pressure: 730 Pa (15.26 psf)

Product Tested By: Intertek, LLC
Report No: P2059.01-201-44
Expiration Date: January 31, 2027

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com