## NOTICE OF PRODUCT CERTIFICATION •



**CERTIFICATION NO:** NI015814.01

**DATE:** 05/30/2023

**CERTIFICATION PROGRAM:** Structural

COMPANY: Quaker

**CODE:** 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products	Series "C200"
504 Highway 63 South	Aluminum French Inswing
Freeburg, MO 65035	Side Hinged Door
	Configuration: XX Glazing: Insulating Glass (Tempered)
	Frame: W-1829mm(72") H-2108mm(83")
	Panel: W-884mm(34.81") H-2032mm(80")
	DLO: W-713mm(28.06") H-1861mm(73.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-09	Class LC-PG50 1829 x 2108 (72 x 83)-LWSHD  Design Pressure: ±2400 Pa (±50 psf)  Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)  Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, LLC
Report No: P6759.02-801-44
Expiration Date: January 31, 2027

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Email: nami@namiinc.com