

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015814  
DATE: 05/30/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Quaker  
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Quaker Window Products</b> <b>504 Highway 63 South</b> <b>Freeburg, MO 65035</b>	<b>Series "C200"</b> <b>Aluminum French Inswing</b> <b>Side Hinged Door</b>  Configuration: XX Glazing: Insulating Glass (Tempered)  Frame: W-1829mm(72") H-2108mm(83") Panel: W-884mm(34.81") H-2032mm(80") DLO: W-713mm(28.06") H-1861mm(73.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>CSA A440S1-09</b>	<b>Class LC-PG30 1829 x 2108 (72 x 83)-SHD</b> <b>Design Pressure: ±1440 Pa (±30 psf)</b> <b>Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)</b> <b>Canadian Infiltration/Exfiltration Level: A2</b>

Product Tested By: Intertek, LLC  
Report No: P6759.01-801-44  
Expiration Date: **January 31, 2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)