

Notice of Product Certification

CERTIFICATION NO.: 2932-004
INITIAL CERTIFICATION DATE: June 19, 2023
REVISION DATE: N/A
REPORT NUMBER: FEW23101498-g
SPECIFICATION: CSA A440.2-19

COMPANY: Fersina Windows
CODE: 2932-1
EXPIRATION DATE: April 27, 2028
PRODUCT SIMULATED BY: WSP
AIR LEAKAGE REPORT NO.: 1278-3D

PRODUCT/SERIES NAME: 1400 Awning **OPERATOR TYPE:** PRAW

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2932-004-0001-01	180-arg97-CCI, ss	0.068(#2)	1.51	0.40	0.48	0.1	30
2932-004-0001-02	180-arg97-CCI, ss, Grids<1 Inch	0.068(#2)	1.51	0.36	0.43	0.1	28
2932-004-0002-01	272-arg97-CCI, ss	0.042(#2)	1.48	0.26	0.44	0.1	22
2932-004-0002-02	272-arg97-CCI, ss, Grids<1 Inch	0.042(#2)	1.48	0.23	0.40	0.1	21
2932-004-0003-01	366-arg97-CCI, ss	0.020(#2)	1.45	0.17	0.40	0.1	18
2932-004-0003-02	366-arg97-CCI, ss, Grids<1 Inch	0.020(#2)	1.45	0.16	0.36	0.1	17
2932-004-0004-01	272-arg97-i89, ss	0.042(#2) 0.149(#4)	1.31	0.25	0.43	0.1	26
2932-004-0004-02	272-arg97-i89, ss, Grids<1 Inch	0.042(#2) 0.149(#4)	1.31	0.23	0.39	0.1	24
2932-004-0005-01	8071-arg97-CCI, ss	0.082(#2)	1.53	0.41	0.49	0.1	30
2932-004-0005-02	8071-arg97-CCI, ss, Grids<1 Inch	0.082(#2)	1.53	0.37	0.44	0.1	28
2932-004-0006-01	180-arg97-CCI-arg97-CCI, ss	0.068(#2)	1.22	0.37	0.44	0.1	34
2932-004-0006-02	180-arg97-CCI-arg97-CCI, ss, Grids<1 Inch	0.068(#2)	1.22	0.33	0.40	0.1	32
2932-004-0007-01	272-arg97-CCI-arg97-CCI, ss	0.042(#2)	1.20	0.24	0.40	0.1	27
2932-004-0007-02	272-arg97-CCI-arg97-CCI, ss, Grids<1 Inch	0.042(#2)	1.20	0.22	0.36	0.1	26
2932-004-0008-01	272-arg97-CCI-arg97-272, ss	0.042(#2, #5)	0.99	0.22	0.35	0.1	31
2932-004-0008-02	272-arg97-CCI-arg97-272, ss, Grids<1 Inch	0.042(#2, #5)	0.99	0.20	0.32	0.1	30
2932-004-0009-01	366-arg97-CCI-arg97-180, ss	0.020(#2) 0.068(#5)	0.99	0.16	0.35	0.1	27
2932-004-0009-02	366-arg97-CCI-arg97-180, ss, Grids<1 Inch	0.020(#2) 0.068(#5)	0.99	0.14	0.31	0.1	26
2932-004-0010-01	180-arg97-CCI-arg97-i89, ss	0.068(#2) 0.149(#6)	1.12	0.36	0.43	0.1	36
2932-004-0010-02	180-arg97-CCI-arg97-i89, ss, Grids<1 Inch	0.068(#2) 0.149(#6)	1.12	0.32	0.39	0.1	34
2932-004-0011-01	272-arg97-CCI-arg97-i89, ss	0.042(#2) 0.149(#6)	1.10	0.23	0.39	0.1	29
2932-004-0011-02	272-arg97-CCI-arg97-i89, ss, Grids<1 Inch	0.042(#2) 0.149(#6)	1.10	0.21	0.35	0.1	28
2932-004-0012-01	366-arg97-CCI-arg97-i89, ss	0.020(#2) 0.149(#6)	1.08	0.16	0.35	0.1	25
2932-004-0012-02	366-arg97-CCI-arg97-i89, ss, Grids<1 Inch	0.020(#2) 0.149(#6)	1.08	0.14	0.32	0.1	24

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2932-004-0013-01	8071-arg97-CCI-arg97-8071, ss	0.082(#2, #5)	1.03	0.36	0.44	0.1	38
2932-004-0013-02	8071-arg97-CCI-arg97-8071, ss, Grids<1 Inch	0.082(#2, #5)	1.03	0.33	0.39	0.1	36

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.
 4794 George Washington Memorial Hwy.
 Hayes, VA 23072
 Tel.: (804) 684-5124
 nami@namiinc.com
 namicertification.com