

# Notice of Product Certification

CERTIFICATION NO.: 839-004  
INITIAL CERTIFICATION DATE: June 8, 2023  
REVISION DATE: N/A  
REPORT NUMBER: SPL22001-17-C\_HSOX-H  
SPECIFICATION: CSA A440.2-19

COMPANY: Profenex  
CODE: 839-1  
EXPIRATION DATE: August 30, 2027  
PRODUCT SIMULATED BY: Veridis Solutions  
AIR LEAKAGE REPORT NO.: AI-04137-E1

PRODUCT/SERIES NAME: Coulissant Simple Hybride - 9020D    OPERATOR TYPE: HSOX

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
839-004-0001-01	GL   3mm_7/8_PCI-arg95-8071   su	0.082(#3)	1.62	0.53	0.59	0.5	34

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. M.', written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
nami@namiinc.com  
namicertification.com