

Notice of Product Certification

CERTIFICATION NO.: 839-007
INITIAL CERTIFICATION DATE: June 8, 2023
REVISION DATE: N/A
REPORT NUMBER: SPL21004-43-C_PRAW-P
SPECIFICATION: CSA A440.2-19

COMPANY: Profenex
CODE: 839-1
EXPIRATION DATE: October 25, 2026
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-04490-A1 Rev. 1

PRODUCT/SERIES NAME: Auvent - PVC

OPERATOR TYPE: PRAW

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
839-007-0001-01	GL 3mm_7/8_PCI-arg95-8071 su	0.082(#3)	1.49	0.48	0.53	0.1	35
839-007-0002-01	GL 3mm_1 1/4_SG400-arg95-PCI-arg95-SG400 su	0.113(#2, #5)	1.02	0.37	0.46	0.1	39

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com