

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015744.01  
DATE: 06/01/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Hoelscher  
CODE: 1765-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Hoelscher Weatherstrip Manufacturing Company, Inc.</b> <b>2400 South Persimmon Street</b> <b>Tomball, TX 77375</b>	<b>Series "HWS 6080 Vertical Lite"</b> <b>Glazed Fiberglass Inswing Double</b> <b>Side-Hinged Doors</b>  Configuration: XX Glazing: Insulated Glass (Tempered) Frame: W-1881mm(74.06") H-2483mm(97.75") Panel: W-927mm(36.50") H-2426mm(95.50") DLO: W-229mm(9") H-1937mm(76.25")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330/E330M-14</b>	<b>Design Pressure: ±2640 Pa (±55 psf)</b>

Product Tested By: Intertek, PLC  
Report No: P8115.01-801-44  
Expiration Date: March 31, 2027

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)