

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015813
DATE: 05/25/2023
CERTIFICATION PROGRAM: Structural
COMPANY: WARREN
CODE: 2890-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Warren Windows & Doors (Guangdong) Co., Ltd. 7 East Industrial Road, Songxia Ind. Park Shishan, Nahai District Foshan Guangdong, China 528200 | Series "Engineer" Aluminum Tilt & Turn Dual-Action Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1219mm(48") H-1829mm(72") Sash: W-1164mm(45.83") H-1774mm(69.83") DLO: W-1048mm(41.27") H-1658mm(1658") |

| SPECIFICATION | PRODUCT RATING |
|----------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19 | Class CW-PG30 1219 x 1829 (48 x 72)-DAW Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.00 psf) Canadian Air Infiltration/Exfiltration Level: A3 |

Product Tested By: Intertek, PLC
Report No: 221110001SHF-006
Expiration Date: **January 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com