

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015820  
**DATE:** 06/19/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Shanghai  
**CODE:** 2590-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Shanghai Superhouse Building Material Co., LTD Number 10, Hangfan Road Pudong New Area, Shanghai China 201314</b>	<b>Series "SP65T"</b> <b>Aluminum Awning Window</b> Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1200mm(47.24") H-1200mm(47.24") Vent: W-1148mm(45.21") H-1148mm(45.21") DLO: W-1003mm(39.49") H-1003mm(39.49")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class CW-PG60 1200 x 1200 (47 x 47)-AP</b> <b>Design Pressure: ±2880 Pa (±60 psf)</b> Water Penetration Resistance Pressure: 580 Pa (12.11 psf)

Product Tested By: Intertek - Shanghai  
Report No: 221123004SHF-001  
Expiration Date: **November 30, 2026**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi D".

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)