

Notice of Product Certification

CERTIFICATION NO.: 1252-003
INITIAL CERTIFICATION DATE: July 25, 2023
REVISION DATE: N/A
REPORT NUMBER: SPL21004-22-C_CSSV-P
SPECIFICATION: CSA A440.2-22


COMPANY: Portes et Fenetres BM Inc.
CODE: 1252-1
EXPIRATION DATE: October 25, 2026
PRODUCT SIMULATED BY: Veridis Solutions Inc.
AIR LEAKAGE REPORT NO.: AI-03741-F1 Rev.3

PRODUCT/SERIES NAME: Battant - PVC

OPERATOR TYPE: CSSV

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1252-003-0001-01	3mm_7/8_PCI-arg95-8071 iu	0.082(#3)	1.50	0.48	0.53	0.1	35

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'Shi D'.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com