

Notice of Product Certification

CERTIFICATION NO.: 874-001
INITIAL CERTIFICATION DATE: July 25, 2023
REVISION DATE: N/A
REPORT NUMBER: SPL21004-15-C_CSSV-H
SPECIFICATION: CSA A440.2-22

COMPANY: Feneco Inc.
CODE: 874-1
EXPIRATION DATE: October 25, 2026
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-03741-X1 Rev. 2

PRODUCT/SERIES NAME: Hybrid Casement - 9000 OPERATOR TYPE: CSSV

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
874-001-0001-01	3mm_7/8_GCl-arg95-8071 im	0.082(#3)	1.58	0.47	0.53	0.1	32
874-001-0002-01	3mm_1 1/4_GCl-arg95-GCl-arg95-8071 im	0.082(#5)	1.26	0.42	0.48	0.1	36
874-001-0003-01	3mm_7/8_GCl-arg95-8071 sp	0.082(#3)	1.54	0.47	0.53	0.1	33
874-001-0004-01	3mm_7/8_STCl-arg95-8071 sp	0.082(#3)	1.54	0.49	0.53	0.1	34

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. M.', is written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com