

# Notice of Product Certification

**CERTIFICATION NO.:** 874-005  
**INITIAL CERTIFICATION DATE:** July 25, 2023  
**REVISION DATE:** N/A  
**REPORT NUMBER:** SPL22001-26-C\_VSSH-P  
**SPECIFICATION:** CSA A440.2-22

**COMPANY:** Feneco Inc.  
**CODE:** 874-1  
**EXPIRATION DATE:** August 31, 2027  
**PRODUCT SIMULATED BY:** Veridis Solutions  
**AIR LEAKAGE REPORT NO.:** AI-04110-A1 Rev.1

**PRODUCT/SERIES NAME:** Guillotine Simple PVC 9620I-9820I    **OPERATOR TYPE:** VSSH

| Product Number  | Manufacturer Product Code                   | Emissivity (Surface #) | U-Factor (Metric) | SHGC(w) | Visible Transmittance (VT) | Air Leakage Average (L75) | Energy Rating |
|-----------------|---|------------------------|-------------------|---------|----------------------------|---------------------------|---------------|
| 874-005-0001-01 | GL  3mm_7/8_GCl-arg95-8071   im             | 0.082(#3)              | 1.62              | 0.52    | 0.59                       | 0.4                       | 34            |
| 874-005-0002-01 | GL  3mm_7/8_GCl-arg95-8071   im   Grids<1"  | 0.082(#3)              | 1.62              | 0.47    | 0.52                       | 0.4                       | 31            |
| 874-005-0003-01 | GL  3mm_7/8_GCl-arg95-8071   im   Grids>1"  | 0.082(#3)              | 1.62              | 0.42    | 0.46                       | 0.4                       | 28            |
| 874-005-0004-01 | GL  3mm_7/8_STCl-arg95-8071   im            | 0.082(#3)              | 1.62              | 0.55    | 0.59                       | 0.4                       | 36            |
| 874-005-0005-01 | GL  3mm_7/8_STCl-arg95-8071   im   Grids<1" | 0.082(#3)              | 1.62              | 0.49    | 0.53                       | 0.4                       | 32            |
| 874-005-0006-01 | GL  3mm_7/8_STCl-arg95-8071   im   Grids>1" | 0.082(#3)              | 1.62              | 0.43    | 0.46                       | 0.4                       | 29            |
| 874-005-0007-01 | GL  3mm_7/8_GCl-arg95-8071   sp             | 0.082(#3)              | 1.58              | 0.52    | 0.59                       | 0.4                       | 35            |
| 874-005-0008-01 | GL  3mm_7/8_GCl-arg95-8071   sp   Grids<1"  | 0.082(#3)              | 1.58              | 0.47    | 0.52                       | 0.4                       | 32            |
| 874-005-0009-01 | GL  3mm_7/8_GCl-arg95-8071   sp   Grids>1"  | 0.082(#3)              | 1.58              | 0.42    | 0.46                       | 0.4                       | 29            |
| 874-005-0010-01 | GL  3mm_7/8_STCl-arg95-8071   sp            | 0.082(#3)              | 1.58              | 0.55    | 0.59                       | 0.4                       | 36            |
| 874-005-0011-01 | GL  3mm_7/8_STCl-arg95-8071   sp   Grids<1" | 0.082(#3)              | 1.58              | 0.49    | 0.53                       | 0.4                       | 33            |
| 874-005-0012-01 | GL  3mm_7/8_STCl-arg95-8071   sp   Grids>1" | 0.082(#3)              | 1.58              | 0.43    | 0.46                       | 0.4                       | 29            |
| 874-005-0013-01 | BF_3mm_7/8_GCl-arg95-8071   im              | 0.082(#3)              | 1.62              | 0.52    | 0.59                       | 0.4                       | 34            |
| 874-005-0014-01 | BF_3mm_7/8_GCl-arg95-8071   im   Grids<1"   | 0.082(#3)              | 1.62              | 0.47    | 0.52                       | 0.4                       | 31            |
| 874-005-0015-01 | BF_3mm_7/8_GCl-arg95-8071   im   Grids>1"   | 0.082(#3)              | 1.62              | 0.42    | 0.46                       | 0.4                       | 28            |
| 874-005-0016-01 | BF_3mm_7/8_STCl-arg95-8071   im             | 0.082(#3)              | 1.62              | 0.55    | 0.59                       | 0.4                       | 36            |
| 874-005-0017-01 | BF_3mm_7/8_STCl-arg95-8071   im   Grids<1"  | 0.082(#3)              | 1.62              | 0.49    | 0.53                       | 0.4                       | 32            |
| 874-005-0018-01 | BF_3mm_7/8_STCl-arg95-8071   im   Grids>1"  | 0.082(#3)              | 1.62              | 0.43    | 0.46                       | 0.4                       | 29            |
| 874-005-0019-01 | BF_3mm_7/8_GCl-arg95-8071   sp              | 0.082(#3)              | 1.58              | 0.52    | 0.59                       | 0.4                       | 35            |
| 874-005-0020-01 | BF_3mm_7/8_GCl-arg95-8071   sp   Grids<1"   | 0.082(#3)              | 1.58              | 0.47    | 0.52                       | 0.4                       | 32            |
| 874-005-0021-01 | BF_3mm_7/8_GCl-arg95-8071   sp   Grids>1"   | 0.082(#3)              | 1.58              | 0.42    | 0.46                       | 0.4                       | 29            |
| 874-005-0022-01 | BF_3mm_7/8_STCl-arg95-8071   sp             | 0.082(#3)              | 1.58              | 0.55    | 0.59                       | 0.4                       | 36            |
| 874-005-0023-01 | BF_3mm_7/8_STCl-arg95-8071   sp   Grids<1"  | 0.082(#3)              | 1.58              | 0.49    | 0.53                       | 0.4                       | 33            |
| 874-005-0024-01 | BF_3mm_7/8_STCl-arg95-8071   sp   Grids>1"  | 0.082(#3)              | 1.58              | 0.43    | 0.46                       | 0.4                       | 29            |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)  
[namicertification.com](http://namicertification.com)