

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015824-R1  
**DATE:** 07/05/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Quaker  
**CODE:** 031-1  
**REVISION DATE:** 12/11/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Quaker Window Products</b> <b>504 Highway 63 South</b> <b>Freeburg, MO 65035</b>	<b>Series "C600/605"</b> <b>Aluminum Outswing Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1524mm(60") Vent: W-878mm(34.56") H-1487mm(58.56") DLO: W-770mm(30.31") H-1378mm(54.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class AW-PG100 914 x 1524 (36 x 60)-C</b> <b>Design Pressure: ±4800 Pa (±100 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)

Product Tested By: Molimo, LLC  
Report No: 12453.02-106-11  
Expiration Date: **June 30, 2027**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023