

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015829
DATE: 07/20/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern Arch
CODE: 1783-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "176 SH SGP" Vinyl Single Hung Window Configuration: O/X Glazing: IG - 3/16" Annealed Glass/1/8" Annealed Glass/0.090" Dupont SGP Interlayer/1/8" Annealed Glass Frame: W-914mm(36") H-1676mm(66") Sash: W-826mm(32.5") H-826mm(32.5") DLO: W-749mm(29.5") H-741mm(29.19")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ± 4309 Pa (± 120 psf) Water Penetration Resistance Test Pressure: 862 Pa (18 psf) Large Missile Impact Rated

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-EAS-23-002
Expiration Date: **June 30, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com