

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015830.01
DATE: 07/20/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "4700/4701 FLIR & 4701 FIR" Aluminum Fixed Lite Configuration: O Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.090" Eastman PVB Interlayer/1/8" Annealed Glass Frame: W-1348mm(53.06") H-1880mm(74") DLO: W-1253mm(49.31") H-1788mm(70.38")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08/11/16 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG60 1348 x 1880* (53 x 74*)-FW FW LC-PG 1348 x 1880* (53 x 74*) Design Pressure: ±2873 Pa (±60 psf) Positive Design Pressure: 3840 Pa (80 psf) Negative Design Pressure: 3840 Pa (80 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) ASTM Impact Rating Design Pressure: ±2349 Pa (±50 psf) Positive Design Pressure: 2349 Pa (50 psf) Negative Design Pressure: 2729 Pa (57 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: 110-26154-1/110-13668-1/110-25962-1
Expiration Date: **July 31, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com