## **NOTICE OF PRODUCT CERTIFICATION**



**CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:** 

NI015831	
07/24/2023	
Structural	
Ply Gem	
1408-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	<b>PRODUCT DESCRIPTION</b>	
Ply Gem Window Group	Series "4712FLIR & 4712FIR & 4812FIR"	
433 North Main Street	Aluminum Single Hung Window	
Rocky Mount, VA 24151	Configuration: O/X Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.090" Eastman PVB Interlayer/1/8" Annealed Glass	
	Frame: W-1346mm(53") H-1829mm(72")	
	Sash: W-1295mm(51") H-914mm(36")	
	DLO: W-1254mm(49.38") H-845mm(33.25")	

SPECIFICATION AAMA 506-06/08/11/16 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-02/04/05/13 ASTM E1996-02/04/06/09/12/14	PRODUCT RATING Class LC-PG50 1346 x 1823 (53 x 72)-H H-R50 1346 x 1823 (53 x 72) Design Pressure: ±2349 Pa (±50 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3360 Pa (70 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) <u>ASTM Impact Rating</u> Design Pressure: ±2349 Pa (±50 psf) Positive Design Pressure: 2349 Pa (50 psf) Negative Design Pressure: 2729 Pa (57 psf) Wind Zone 3 - Missile Level D
Product Tested By:National Certified TestingReport No:110-26152-1	Laboratories

Expiration Date: July 31, 2024

Shi)

Administrator's Signature:

NATIONAL ACCREDITATION AND **MANAGEMENT INSTITUTE, INC.** 4794 George Washington Memorial Highway

> Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com