

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015832.09  
**DATE:** 07/25/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>Simonton Windows</b> <b>520 Weston Parkway, Suite 300</b> <b>Cary, NC 27513</b>	<b>Series "Ply Gem Perspective/ Simonton MaxView"</b> <b>Vinyl Sliding Glass Door</b> <b>(w/o Sill Riser)</b>  Configuration: XX-XX Glazing: Insulating Glass (Tempered)  Frame: W-6053mm(238.31") H-2426mm(95.5") Panel: W-1553mm(61.13") H-2364mm(93.06") DLO: W-1324mm(52.13") H-2135mm(84.06")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG20 6053 x 2426 (238 x 96)-SD</b> <b>Design Pressure: ±958 Pa (±20 psf)</b> <b>Positive Design Pressure: 1680 Pa (35 psf)</b> <b>Negative Design Pressure: 1680 Pa (35 psf)</b> <b>Water Penetration Resistance Test Pressure: 150 Pa (3.13 psf)</b>

Product Tested By: Molimo Architectural Product Testing  
Report No: 11835.15-106-11  
Expiration Date: **December 31, 2026**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)