

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015832.13
DATE: 07/25/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Ply Gem Window Group Simonton Windows 520 Weston Parkway, Suite 300 Cary, NC 27513</p>	<p style="text-align: center;">Series "Ply Gem Perspective/ Simonton MaxView"</p> <p style="text-align: center;">Vinyl Sliding Glass Door</p> <p style="text-align: center;">(3-Track w/Exterior Pocket)</p> <p style="text-align: center;">Configuration: XXX-XXXX Glazing: IG-3/16" Tempered Glass/1/8" Heat Strengthened Glass/0.105" Eastman Saflex PVB Interlayer/1/8" Heat Strengthened Glass or 3/16" Tempered Glass/5/32" Heat Strengthened Glass/0.105" Eastman Saflex PVB Interlayer/5/32" Heat Strengthened Glass</p> <p>Frame: W-7126mm(280.56") H-3035mm(119.5")</p> <p>Panel: W-1248mm(49.13") H-2974mm(117.06")</p> <p>DLO: W-1019mm(40.13") H-2745mm(108.06")</p>

SPECIFICATION	PRODUCT RATING
<p>TAS 201/202/203-94</p>	<p>Design Pressure: ±2880 Pa (±60 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.2 psf) Large Missile Impact Rated</p>

Product Tested By: Molimo Architectural Product Testing
Report No: 11835.19-106-11
Expiration Date: March 31, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com