

Notice of Product Certification

CERTIFICATION NO.: 2957-008
INITIAL CERTIFICATION DATE: August 3, 2023
REVISION DATE: N/A
REPORT NUMBER: SPL21004-45-C_CSSV-P
SPECIFICATION: CSA A440.2-22

COMPANY: San Fenestration Inc.
CODE: 2957-1
EXPIRATION DATE: October 25, 2026
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-03741-F1 Rev.3

PRODUCT/SERIES NAME: Battant - PVC

OPERATOR TYPE: CSSV

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2957-008-0001-01	GL 3mm_1 1/4_GCl-arg95-GCl-arg95-8071 im	0.082(#5)	1.22	0.42	0.48	0.1	37
2957-008-0002-01	GL 3mm_1 1/4_GCl-arg95-GCl-arg95-8071 im Grids<1"	0.082(#5)	1.22	0.39	0.43	0.1	36
2957-008-0003-01	GL 3mm_7/8_GCl-arg95-8071 sp	0.082(#3)	1.48	0.47	0.53	0.1	35
2957-008-0004-01	GL 3mm_7/8_GCl-arg95-8071 sp Grids<1"	0.082(#3)	1.48	0.43	0.47	0.1	32

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com