

# Notice of Product Certification

**CERTIFICATION NO.:** 2957-009  
**INITIAL CERTIFICATION DATE:** August 3, 2023  
**REVISION DATE:** N/A  
**REPORT NUMBER:** SPL21004-45-C\_LFIXD-P  
**SPECIFICATION:** CSA A440.2-22

**COMPANY:** San Fenestration Inc.  
**CODE:** 2957-1  
**EXPIRATION DATE:** November 11, 2027  
**PRODUCT SIMULATED BY:** Veridis Solutions  
**AIR LEAKAGE REPORT NO.:** AI-03741-B1 Rev.3

**PRODUCT/SERIES NAME:** Grand Fixe PVC      **OPERATOR TYPE:** FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2957-009-0001-01	GL_3mm_1 1/4_GCl-arg95-GCl-arg95-8071   ms	0.082(#5)	1.20	0.50	0.57	0.0	43
2957-009-0002-01	GL_3mm_1 1/4_GCl-arg95-GCl-arg95-8071   ms   Grids<1"	0.082(#5)	1.20	0.45	0.51	0.0	40
2957-009-0003-01	GL_3mm_7/8_GCl-arg95-8071   sp	0.082(#3)	1.53	0.55	0.62	0.0	38
2957-009-0004-01	GL_3mm_7/8_GCl-arg95-8071   sp, Grids<1"	0.082(#3)	1.53	0.50	0.55	0.0	35

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
nami@namiinc.com  
namicertification.com