

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012057.01-R4  
**DATE:** 07/10/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Fleetwood  
**CODE:** 1855-1  
**REVISION DATE:** 06/22/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Fleetwood Windows and Doors</b>  <b>1 Fleetwood Way</b>  <b>Corona, CA 92879</b>	<b>Series "Norwood 3070"</b>  <b>Aluminum Sliding Glass/Pocket Door</b>  Configuration: XXX Glazing: Monolithic-1/4" Annealed Glass/0.090" DuPont SentryGlas Plus Interlayer/ 1/4" Annealed Glass  Frame: W-3658mm(144") H-3658mm(144") DLO: W-1105mm(43.5") H-3442mm(135.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b> <b>ASTM E1886-05/E1996-06</b> <b>TAS 201/202/203-94</b>	<b>Class LC-PG55 3658 x 3658 (144 x 144)-SD</b> <b>Design Pressure: 2633 Pa (55 psf)</b> <b>Negative Design Pressure: 2873 Pa (60 psf)</b> <b>Water Penetration Resistance Test Pressure: 395 Pa(8.25 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b> <b>Wind Zone 4 - Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01991010/TEL 01991009/TEL 01991011  
Expiration Date: February 28, 2026

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)