

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015842
DATE: 08/10/2023
CERTIFICATION PROGRAM: Structural
COMPANY: EOSS System
CODE: 2965-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
EOSS System Doors and Windows (Shandong) Co., Ltd. 7027 Dongtai Road, Dongcheng Street Weifang, Shandong, China 262600	Series "ES70 System" Aluminum Side-Hinged Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1000mm(39.37") H-2500mm(98.43") Panel: W-932mm(36.69") H-2455mm(96.65") DLO: W-742mm(29.21") H-2265mm(89.17")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19	Class CW-PG40 1000 x 2500 (39 x 98)-SHD Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, LLC
Report No: 211129011SHF-003
Expiration Date: August 31, 2026

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com