

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015845
DATE: 08/10/2023
CERTIFICATION PROGRAM: Structural
COMPANY: EOSS System
CODE: 2965-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
EOSS System Doors and Windows (Shandong) Co., Ltd. 7027 Dongtai Road, Dongcheng Street Weifang, Shandong, China 262600	Series "ES70 System" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1500mm(59.06") H-2500mm(98.43") DLO: W-1308mm(51.50") H-2408mm(94.80")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG50 1500 x 2500 (59 x 98)-FW Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)

Product Tested By: Intertek, LLC
Report No: 211129011SHF-010
Expiration Date: **July 31, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com