

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015846
DATE: 08/10/2023
CERTIFICATION PROGRAM: Structural
COMPANY: EOSS System
CODE: 2965-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
EOSS System Doors and Windows (Shandong) Co., Ltd. 7027 Dongtai Road, Dongcheng Street Weifang, Shandong, China 262600	Series "N152" Aluminum Sliding Door Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-4550mm(179.13") H-2600mm(102.36") Panel: W-2278mm(89.69") H-2504mm(98.58") DLO: W-2104mm(82.83") H-2334mm(91.89")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG30 4550 x 2600 (179 x 102)-SD Design Pressure: ± 1440 Pa (± 30 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, LLC
Report No: 211129011SHF-012
Expiration Date: August 31, 2026

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com