## NOTICE OF PRODUCT CERTIFICATION '



**CERTIFICATION NO: NI015848** 

**DATE:** 08/16/2023

**CERTIFICATION PROGRAM:** Structural

**COMPANY:** Linea Rossa

**CODE: 2749-1** 

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Linea Rossa Windows and Doors	Series "LR-530F"
1850 Northwest 84th Avenue, Suite 114	Aluminum Fixed Window
Doral, FL 33126	(Thermally Broken)
	Configuration: OOO Glazing: IG - 5/32" Heat Strengthened Glass/5/32" Heat Strengthened Glass/0.090" SentryGlass Plus Interlayer/5/32" Heat Strengthened Glass
	Frame: W-3200mm(126") H-2286mm(90")
	Panel: W-1067mm(42") H-2286mm(90")
	DLO: W-953mm(37.5") H-2172mm(85.5")

SPECIFICATION	PRODUCT RATING
ASTM E1886-13a/19 ASTM E1996-17/20 TAS 201/202/203-94	Design Pressure: ±3840 Pa (±80 psf) Water Penetration Resistance Test Pressure: 646 Pa (13.5 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: QAI Laboratories

Report No: 13123

Expiration Date: August 31, 2026

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com