NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI015850

DATE:

08/21/2023

CERTIFICATION PROGRAM:

Structural

COMPANY:

Quaker

CODE: <u>031-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DESC	CRIPTION
Quaker Window Products	Series "M2055"		
504 Highway 63 South	Aluminum Sliding Door		
Freeburg, MO 65035			
		Configuration: Glazing: Insulating Gla	
	Frame:	W-4572mm(180")	H-3658mm(144")
	Panel:	W-1557mm(61.31")	H-3612mm(142.19")
	DLO:	W-1403mm(55.25")	H-3426mm(134.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG15 4572 x 3658 (180 x 144)-SD Design Pressure: ±720 Pa (±15 psf) Water Penetration Resistance Test Pressure: 215 Pa (4.50 psf)

Product Tested By: Intertek, LLC
Report No: Q1192.01-801-44
Expiration Date: June 30, 2027

Administrator's Signature: _

She

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

> Tel: (804) 684-5124 Email: nami@namiinc.com