## NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO: NI015851** 

**DATE:** 08/21/2023

**CERTIFICATION PROGRAM: Structural** 

**COMPANY:** KBP Distribution

CODE: 2937-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
KBP Distribution, Inc.	Model "3068 TT" Glazed	
dba High Rock Doors	<b>Inswing Fiberglass Entrance</b>	
54 Denver Road	Door Assembly	
Denver, PA 17517		
	Configuration: X Glazing: Insulating Glass (Tempered)	
	Frame: W-959mm(37.75") H-2083mm(82")	
	Panel: W-933mm(36.75") H-2013mm(79.25")	
	DLO: W-530mm(20.88") H-1597mm(62.88")	)

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/17 Federal Manufactured Home Construction & Safety Standard 3280.305 (applicable sub-sections)	Manufactured Housing: Wind Zone III Design Wind Pressure Rating:±58 psf

Product Tested By: Intertek, PLC Report No: P6986.02-109-44 Expiration Date: March 31, 2025

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com