
NOTICE OF PRODUCT CERTIFICATION '



CERTIFICATION NO: NI015856

DATE: 08*i*

08/29/2023

CERTIFICATION PROGRAM:

Structural

COMPANY:

YKK AP America

CODE:

860-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION		
YKK AP America, Inc.	StyleView® Classic		
101 Marietta Street NW, Suite 2100	Fixed Vinyl Window		
Atlanta, GA 30303			
	Configuration: O Glazing: Insulating Glass (Annealed)		
	Frame:	W-1816mm(71.50")	H-2426mm(95.50")
	DLO:	W-1683mm(66.25")	H-2292mm(90.25")

PRODUCT RATING	
Class R-PG35 1816 x 2426 (72 x 96)-FW	
Design Pressure: ±1680 Pa (±35 psf) ter Penetration Resistance Test Pressure: 360 Pa (7.50 psf)	

Product Tested By: Intertek, PLC
Report No: P5942.08-550-44
Expiration Date: December 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC

4794 George Washington Memorial Highway Hayes, VA 23072

> Tel: (804) 684-5124 Email: nami@namiinc.com