

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015861  
DATE: 08/30/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: ABI Windows  
CODE: 2942-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ABI Windows, LLC</b> <b>1121 Fulwiler Road</b> <b>Abilene, Texas 79603</b>	<b>Series "500"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1816mm(71.50") H-1816mm(71.50") DLO: W-1727mm(68") H-1727mm(68")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class R-PG50 1816 x 1816 (72 x 72)-FW</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: PRI Construction Materials Technologies, LLC  
Report No: 2602T0004  
Expiration Date: July 31, 2027

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)