

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015868-R1  
**DATE:** 08/30/2023  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** Builders First  
**CODE:** 1665-1  
**REVISION DATE:** 09/07/2023  
**EXPIRATION DATE:** 08/31/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Builders First Source</b> <b>399 Northpoint Parkway</b> <b>Acworth, GA 30102</b>	<b>TruStile 20-Minute</b> <b>MDF Side Hinged Door</b>  Manufacture Specific Fire Door for Single & Double Swing Installation in 20-Minute Locations  <b>Single Door Maximum Size: 4'0" x 8'0"</b> <b>Double Door Maximum Size: 8'0" x 8'0"</b>

SPECIFICATION	PRODUCT RATING
<b>CAN / ULC S104 (2015 (R2020))</b> <b>UL 10C (2016)</b> <b>NFPA 252 (2017)</b>	<b>20-Minute Positive Pressure</b> <b>With or Without Hose Stream</b> <b>Category A - No Additional Edge-Sealing Required</b>

TEST REPORT
<b>Intertek Test Report No(s): 3072181, 3134475COQ-003</b>

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)