

Notice of Product Certification

CERTIFICATION NO.: 1181-003
INITIAL CERTIFICATION DATE: September 19, 2023
REVISION DATE: N/A
REPORT NUMBER: TPE22003-1-C_HSOX-1
SPECIFICATION: CSA A440.2-19

COMPANY: Gerard Milette, Inc.
CODE: 1181-1
EXPIRATION DATE: October 28, 2027
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-04587-B1

PRODUCT/SERIES NAME: C6000 Coulissante Simple PVC-Hybride **OPERATOR TYPE:** HSOX

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1181-003-0001-01	PVC, 3mm_7/8_PCI-arg95-8071#3, iu	0.082(#3)	1.64	0.54	0.60	0.6	34
1181-003-0002-01	PVC, 3mm_7/8_PCI-arg95-8071#3, iu, Grids<1"	0.082(#3)	1.64	0.48	0.53	0.6	31
1181-003-0003-01	PVC, 3mm_7/8_PCI-arg95-PTLX#3, iu	0.082(#3)	1.64	0.55	0.59	0.6	35
1181-003-0004-01	PVC, 3mm_7/8_PCI-arg95-PTLX#3, iu, Grids<1"	0.082(#3)	1.64	0.49	0.52	0.6	31
1181-003-0005-01	PVC, 3mm_7/8_70/36#2-arg95-PCI, iu	0.036(#2)	1.57	0.29	0.52	0.6	21
1181-003-0006-01	PVC, 3mm_7/8_70/36#2-arg95-PCI, iu, Grids<1"	0.036(#2)	1.57	0.26	0.46	0.6	19
1181-003-0007-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, iu	0.036(#2)	1.33	0.27	0.48	0.6	25
1181-003-0008-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, iu, Grids<1"	0.036(#2)	1.33	0.24	0.43	0.6	24
1181-003-0009-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, iu	0.036(#2) 0.036(#5)	1.10	0.25	0.41	0.6	29
1181-003-0010-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, iu, Grids<1"	0.036(#2) 0.036(#5)	1.10	0.22	0.36	0.6	27
1181-003-0011-01	PVC, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, iu	0.082(#2) 0.082(#5)	1.15	0.44	0.53	0.6	39
1181-003-0012-01	PVC, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, iu, Grids<1"	0.082(#2) 0.082(#5)	1.15	0.39	0.47	0.6	36
1181-003-0013-01	PVC, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, iu	0.082(#5)	1.36	0.49	0.55	0.6	37
1181-003-0014-01	PVC, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, iu, Grids<1"	0.082(#5)	1.36	0.44	0.49	0.6	34
1181-003-0015-01	PVC, 3mm_7/8_PCI-arg95-8071#3, ms	0.082(#3)	1.65	0.54	0.60	0.6	34
1181-003-0016-01	PVC, 3mm_7/8_PCI-arg95-8071#3, ms, Grids<1"	0.082(#3)	1.65	0.48	0.53	0.6	30
1181-003-0017-01	PVC, 3mm_7/8_PCI-arg95-PTLX#3, ms	0.082(#3)	1.65	0.55	0.59	0.6	34
1181-003-0018-01	PVC, 3mm_7/8_PCI-arg95-PTLX#3, ms, Grids<1"	0.082(#3)	1.65	0.49	0.52	0.6	31
1181-003-0019-01	PVC, 3mm_7/8_70/36#2-arg95-PCI, ms	0.036(#2)	1.58	0.29	0.52	0.6	21
1181-003-0020-01	PVC, 3mm_7/8_70/36#2-arg95-PCI, ms, Grids<1"	0.036(#2)	1.58	0.26	0.46	0.6	19
1181-003-0021-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, ms	0.036(#2)	1.35	0.27	0.48	0.6	25
1181-003-0022-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, ms, Grids<1"	0.036(#2)	1.35	0.24	0.43	0.6	23
1181-003-0023-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, ms	0.036(#2) 0.036(#5)	1.12	0.25	0.41	0.6	29
1181-003-0024-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, ms, Grids<1"	0.036(#2) 0.036(#5)	1.12	0.22	0.36	0.6	27
1181-003-0025-01	PVC, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, ms	0.082(#2) 0.082(#5)	1.17	0.44	0.53	0.6	39

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1181-003-0026-01	PVC, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, ms, Grids<1"	0.082(#2) 0.082(#5)	1.17	0.39	0.47	0.6	36
1181-003-0027-01	PVC, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, ms	0.082(#5)	1.38	0.49	0.55	0.6	37
1181-003-0028-01	PVC, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, ms, Grids<1"	0.082(#5)	1.38	0.44	0.49	0.6	34
1181-003-0029-01	PVC, 3mm_7/8_PCI-arg95-8071#3, sw	0.082(#3)	1.60	0.54	0.60	0.6	35
1181-003-0030-01	PVC, 3mm_7/8_PCI-arg95-8071#3, sw, Grids<1"	0.082(#3)	1.60	0.48	0.53	0.6	32
1181-003-0031-01	PVC, 3mm_7/8_PCI-arg95-PTLX#3, sw	0.082(#3)	1.60	0.55	0.59	0.6	36
1181-003-0032-01	PVC, 3mm_7/8_PCI-arg95-PTLX#3, sw, Grids<1"	0.082(#3)	1.60	0.49	0.52	0.6	32
1181-003-0033-01	PVC, 3mm_7/8_70/36#2-arg95-PCI, sw	0.036(#2)	1.53	0.29	0.52	0.6	22
1181-003-0034-01	PVC, 3mm_7/8_70/36#2-arg95-PCI, sw, Grids<1"	0.036(#2)	1.53	0.26	0.46	0.6	20
1181-003-0035-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, sw	0.036(#2)	1.29	0.27	0.48	0.6	26
1181-003-0036-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, sw, Grids<1"	0.036(#2)	1.29	0.24	0.43	0.6	24
1181-003-0037-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, sw	0.036(#2) 0.036(#5)	1.06	0.25	0.41	0.6	30
1181-003-0038-01	PVC, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, sw, Grids<1"	0.036(#2) 0.036(#5)	1.06	0.22	0.36	0.6	28
1181-003-0039-01	PVC, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, sw	0.082(#2) 0.082(#5)	1.11	0.44	0.53	0.6	40
1181-003-0040-01	PVC, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, sw, Grids<1"	0.082(#2) 0.082(#5)	1.11	0.39	0.47	0.6	37
1181-003-0041-01	PVC, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, sw	0.082(#5)	1.32	0.49	0.55	0.6	38
1181-003-0042-01	PVC, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, sw, Grids<1"	0.082(#5)	1.32	0.44	0.49	0.6	35
1181-003-0043-01	PVC, 3mm_1 1/8_PTLX#2-arg95-PCI-arg95-PTLX#5, sw	0.082(#2) 0.082(#5)	1.11	0.44	0.52	0.6	40
1181-003-0044-01	PVC, 3mm_1 1/8_PTLX#2-arg95-PCI-arg95-PTLX#5, sw,Grids<1"	0.082(#2) 0.082(#5)	1.11	0.40	0.46	0.6	38
1181-003-0045-01	PVC, 3mm_1 1/8_PCI-arg95-PCI-arg95-PTLX#5, sw	0.082(#5)	1.32	0.50	0.54	0.6	39
1181-003-0046-01	PVC, 3mm_1 1/8_PCI-arg95-PCI-arg95-PTLX#5, sw,Grids<1"	0.082(#5)	1.32	0.45	0.48	0.6	36
1181-003-0047-01	HYB, 3mm_7/8_PCI-arg95-8071#3, iu	0.082(#3)	1.64	0.54	0.60	0.6	34
1181-003-0048-01	HYB, 3mm_7/8_PCI-arg95-8071#3, iu,Grids<1"	0.082(#3)	1.64	0.48	0.53	0.6	31
1181-003-0049-01	HYB, 3mm_7/8_PCI-arg95-PTLX#3, iu	0.082(#3)	1.64	0.55	0.59	0.6	35
1181-003-0050-01	HYB, 3mm_7/8_PCI-arg95-PTLX#3, iu,Grids<1"	0.082(#3)	1.64	0.49	0.52	0.6	31
1181-003-0051-01	HYB, 3mm_7/8_70/36#2-arg95-PCI, iu	0.036(#2)	1.57	0.29	0.52	0.6	21
1181-003-0052-01	HYB, 3mm_7/8_70/36#2-arg95-PCI, iu,Grids<1"	0.036(#2)	1.57	0.26	0.46	0.6	19
1181-003-0053-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, iu	0.036(#2)	1.33	0.27	0.48	0.6	25
1181-003-0054-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, iu,Grids<1"	0.036(#2)	1.33	0.24	0.43	0.6	24
1181-003-0055-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, iu	0.036(#2) 0.036(#5)	1.10	0.25	0.41	0.6	29
1181-003-0056-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, iu,Grids<1"	0.036(#2) 0.036(#5)	1.10	0.22	0.36	0.6	27
1181-003-0057-01	HYB, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, iu	0.082(#2) 0.082(#5)	1.15	0.44	0.53	0.6	39
1181-003-0058-01	HYB, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, iu,Grids<1"	0.082(#2) 0.082(#5)	1.15	0.39	0.47	0.6	36
1181-003-0059-01	HYB, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, iu	0.082(#5)	1.36	0.49	0.55	0.6	37
1181-003-0060-01	HYB, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, iu,Grids<1"	0.082(#5)	1.36	0.44	0.49	0.6	34
1181-003-0061-01	HYB, 3mm_7/8_PCI-arg95-8071#3, ms	0.082(#3)	1.65	0.54	0.60	0.6	34
1181-003-0062-01	HYB, 3mm_7/8_PCI-arg95-8071#3, ms,Grids<1"	0.082(#3)	1.65	0.48	0.53	0.6	30
1181-003-0063-01	HYB, 3mm_7/8_PCI-arg95-PTLX#3, ms	0.082(#3)	1.65	0.55	0.59	0.6	34
1181-003-0064-01	HYB, 3mm_7/8_PCI-arg95-PTLX#3, ms,Grids<1"	0.082(#3)	1.65	0.49	0.52	0.6	31
1181-003-0065-01	HYB, 3mm_7/8_70/36#2-arg95-PCI, ms	0.036(#2)	1.58	0.29	0.52	0.6	21

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1181-003-0066-01	HYB, 3mm_7/8_70/36#2-arg95-PCI, ms,Grids<1"	0.036(#2)	1.58	0.26	0.46	0.6	19
1181-003-0067-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, ms	0.036(#2)	1.35	0.27	0.48	0.6	25
1181-003-0068-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, ms,Grids<1"	0.036(#2)	1.35	0.24	0.43	0.6	23
1181-003-0069-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, ms	0.036(#2) 0.036(#5)	1.12	0.25	0.41	0.6	29
1181-003-0070-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, ms,Grids<1"	0.036(#2) 0.036(#5)	1.12	0.22	0.36	0.6	27
1181-003-0071-01	HYB, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, ms	0.082(#2) 0.082(#5)	1.17	0.44	0.53	0.6	39
1181-003-0072-01	HYB, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, ms,Grids<1"	0.082(#2) 0.082(#5)	1.17	0.39	0.47	0.6	36
1181-003-0073-01	HYB, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, ms	0.082(#5)	1.38	0.49	0.55	0.6	37
1181-003-0074-01	HYB, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, ms,Grids<1"	0.082(#5)	1.38	0.44	0.49	0.6	34
1181-003-0075-01	HYB, 3mm_7/8_PCI-arg95-8071#3, sw	0.082(#3)	1.60	0.54	0.60	0.6	35
1181-003-0076-01	HYB, 3mm_7/8_PCI-arg95-8071#3, sw,Grids<1"	0.082(#3)	1.60	0.48	0.53	0.6	32
1181-003-0077-01	HYB, 3mm_7/8_PCI-arg95-PTLX#3, sw	0.082(#3)	1.60	0.55	0.59	0.6	36
1181-003-0078-01	HYB, 3mm_7/8_PCI-arg95-PTLX#3, sw,Grids<1"	0.082(#3)	1.60	0.49	0.52	0.6	32
1181-003-0079-01	HYB, 3mm_7/8_70/36#2-arg95-PCI, sw	0.036(#2)	1.53	0.29	0.52	0.6	22
1181-003-0080-01	HYB, 3mm_7/8_70/36#2-arg95-PCI, sw,Grids<1"	0.036(#2)	1.53	0.26	0.46	0.6	20
1181-003-0081-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, sw	0.036(#2)	1.29	0.27	0.48	0.6	26
1181-003-0082-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-PCI, sw,Grids<1"	0.036(#2)	1.29	0.24	0.43	0.6	24
1181-003-0083-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, sw	0.036(#2) 0.036(#5)	1.06	0.25	0.41	0.6	30
1181-003-0084-01	HYB, 3mm_1 1/8_70/36#2-arg95-PCI-arg95-70/36#5, sw,Grids<1"	0.036(#2) 0.036(#5)	1.06	0.22	0.36	0.6	28
1181-003-0085-01	HYB, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, sw	0.082(#2) 0.082(#5)	1.11	0.44	0.53	0.6	40
1181-003-0086-01	HYB, 3mm_1 1/8_80/71#2-arg95-PCI-arg95-80/71#5, sw,Grids<1"	0.082(#2) 0.082(#5)	1.11	0.39	0.47	0.6	37
1181-003-0087-01	HYB, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, sw	0.082(#5)	1.32	0.49	0.55	0.6	38
1181-003-0088-01	HYB, 3mm_1 1/8_PCI-arg95-PCI-arg95-80/71#5, sw,Grids<1"	0.082(#5)	1.32	0.44	0.49	0.6	35
1181-003-0089-01	HYB, 3mm_1 1/8_PTLX#2-arg95-PCI-arg95-PTLX#5, sw	0.082(#2) 0.082(#5)	1.11	0.44	0.52	0.6	40
1181-003-0090-01	HYB, 3mm_1 1/8_PTLX#2-arg95-PCI-arg95-PTLX#5, sw,Grids<1"	0.082(#2) 0.082(#5)	1.11	0.40	0.46	0.6	38
1181-003-0091-01	HYB, 3mm_1 1/8_PCI-arg95-PCI-arg95-PTLX#5, sw	0.082(#5)	1.32	0.50	0.54	0.6	39
1181-003-0092-01	HYB, 3mm_1 1/8_PCI-arg95-PCI-arg95-PTLX#5, sw,Grids<1"	0.082(#5)	1.32	0.45	0.48	0.6	36

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S.M.D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.
 4794 George Washington Memorial Hwy.
 Hayes, VA 23072
 Tel.: (804) 684-5124
 nami@namiinc.com
 namicertification.com