

Notice of Product Certification

CERTIFICATION NO.: 1290-004
INITIAL CERTIFICATION DATE: September 26, 2023
REVISION DATE: N/A
REPORT NUMBER: TPE23008-6-C_PRAW-a-27
SPECIFICATION: CSA A440.2-22

COMPANY: Anderson Windows
CODE: 1290-1
EXPIRATION DATE: August 1, 2028
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-03661-P1

PRODUCT/SERIES NAME: 4600 PVC (AWN) **OPERATOR TYPE:** PRAW

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1290-004-0001-01	3mm, 7-8, GCl-arg95-8071#3, ms	0.082(#3)	1.55	0.47	0.52	0.1	33
1290-004-0002-01	3mm, 7-8, GCl-arg95-8071#3, ms, Grids < 1"	0.082(#3)	1.55	0.42	0.47	0.1	30
1290-004-0003-01	3mm, 7-8, GCl-arg95-8071#3, ms, Grids >= 1"	0.082(#3)	1.55	0.38	0.42	0.1	28
1290-004-0004-01	3mm, 7-8, GCl-arg95-8071#3, ms, SDL < 1"	0.082(#3)	1.55	0.42	0.47	0.1	30
1290-004-0005-01	3mm, 7-8, GCl-arg95-8071#3, ms, SDL >= 1"	0.082(#3)	1.55	0.38	0.42	0.1	28
1290-004-0006-01	3mm, 1 1-4, 8071#2-arg95-GCl-arg95-8071#5, ms	0.082(#2) 0.082(#5)	1.05	0.38	0.47	0.1	39
1290-004-0007-01	3mm, 1 1-4, 8071#2-arg95-GCl-arg95-8071#5, ms, Grids < 1"	0.082(#2) 0.082(#5)	1.05	0.35	0.42	0.1	37
1290-004-0008-01	3mm, 1 1-4, 8071#2-arg95-GCl-arg95-8071#5, ms, Grids >= 1"	0.082(#2) 0.082(#5)	1.05	0.32	0.38	0.1	35
1290-004-0009-01	3mm, 1 1-4, 8071#2-arg95-GCl-arg95-8071#5, ms, SDL < 1"	0.082(#2) 0.082(#5)	1.05	0.35	0.42	0.1	37
1290-004-0010-01	3mm, 1 1-4, 8071#2-arg95-GCl-arg95-8071#5, ms, SDL >= 1"	0.082(#2) 0.082(#5)	1.05	0.32	0.38	0.1	35
1290-004-0011-01	3mm, 1 1-4, GCl-arg95-GCl-arg95-8071#5, ms	0.082(#5)	1.24	0.42	0.48	0.1	37
1290-004-0012-01	3mm, 1 1-4, GCl-arg95-GCl-arg95-8071#5, ms, Grids < 1"	0.082(#5)	1.24	0.38	0.43	0.1	35
1290-004-0013-01	3mm, 1 1-4, GCl-arg95-GCl-arg95-8071#5, ms, Grids >= 1"	0.082(#5)	1.24	0.34	0.39	0.1	32
1290-004-0014-01	3mm, 1 1-4, GCl-arg95-GCl-arg95-8071#5, ms, SDL < 1"	0.082(#5)	1.24	0.38	0.43	0.1	35
1290-004-0015-01	3mm, 1 1-4, GCl-arg95-GCl-arg95-8071#5, ms, SDL >= 1"	0.082(#5)	1.24	0.34	0.39	0.1	32
1290-004-0016-01	3mm, 1 1-4, GCl-arg95-GCl-arg95-LOF#5, ms	0.164(#5)	1.30	0.44	0.46	0.1	37
1290-004-0017-01	3mm, 1 1-4, GCl-arg95-GCl-arg95-LOF#5, ms, Grids < 1"	0.164(#5)	1.30	0.40	0.41	0.1	34
1290-004-0018-01	3mm, 1 1-4, GCl-arg95-GCl-arg95-LOF#5, ms, Grids >= 1"	0.164(#5)	1.30	0.36	0.37	0.1	32
1290-004-0019-01	3mm, 1 1-4, GCl-arg95-GCl-arg95-LOF#5, ms, SDL < 1"	0.164(#5)	1.30	0.40	0.41	0.1	34
1290-004-0020-01	3mm, 1 1-4, GCl-arg95-GCl-arg95-LOF#5, ms, SDL >= 1"	0.164(#5)	1.30	0.36	0.37	0.1	32
1290-004-0021-01	3mm, 7-8, GCl-arg95-8071#3, dl	0.082(#3)	1.53	0.47	0.52	0.1	33
1290-004-0022-01	3mm, 7-8, GCl-arg95-8071#3, dl, Grids < 1"	0.082(#3)	1.53	0.42	0.47	0.1	31
1290-004-0023-01	3mm, 7-8, GCl-arg95-8071#3, dl, Grids >= 1"	0.082(#3)	1.53	0.38	0.42	0.1	28
1290-004-0024-01	3mm, 7-8, GCl-arg95-8071#3, dl, SDL < 1"	0.082(#3)	1.53	0.42	0.47	0.1	31
1290-004-0025-01	3mm, 7-8, GCl-arg95-8071#3, dl, SDL >= 1"	0.082(#3)	1.53	0.38	0.42	0.1	28

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1290-004-0026-01	3mm, 7-8, GCl-arg95-LOF#3, dl	0.164(#3)	1.64	0.49	0.50	0.1	32
1290-004-0027-01	3mm, 7-8, GCl-arg95-LOF#3, dl, Grids < 1"	0.164(#3)	1.64	0.44	0.45	0.1	29
1290-004-0028-01	3mm, 7-8, GCl-arg95-LOF#3, dl, Grids >= 1"	0.164(#3)	1.64	0.40	0.41	0.1	27
1290-004-0029-01	3mm, 7-8, GCl-arg95-LOF#3, dl, SDL < 1"	0.164(#3)	1.64	0.44	0.45	0.1	29
1290-004-0030-01	3mm, 7-8, GCl-arg95-LOF#3, dl, SDL >= 1"	0.164(#3)	1.64	0.40	0.41	0.1	27
1290-004-0031-01	3mm, 7-8, GCl-arg95-LOF#3, ms	0.164(#3)	1.66	0.49	0.50	0.1	32
1290-004-0032-01	3mm, 7-8, GCl-arg95-LOF#3, ms, Grids < 1"	0.164(#3)	1.66	0.44	0.45	0.1	29
1290-004-0033-01	3mm, 7-8, GCl-arg95-LOF#3, ms, Grids >= 1"	0.164(#3)	1.66	0.40	0.41	0.1	27
1290-004-0034-01	3mm, 7-8, GCl-arg95-LOF#3, ms, SDL < 1"	0.164(#3)	1.66	0.44	0.45	0.1	29
1290-004-0035-01	3mm, 7-8, GCl-arg95-LOF#3, ms, SDL >= 1"	0.164(#3)	1.66	0.40	0.41	0.1	27
1290-004-0036-01	3mm, 1 1-4, GCl-arg95-8071#3-arg95-8071#5, ms	0.082(#3) 0.082(#5)	1.05	0.40	0.47	0.1	40
1290-004-0037-01	3mm, 1 1-4, GCl-arg95-8071#3-arg95-8071#5, ms, Grids < 1"	0.082(#3) 0.082(#5)	1.05	0.37	0.42	0.1	38
1290-004-0038-01	3mm, 1 1-4, GCl-arg95-8071#3-arg95-8071#5, ms, Grids >= 1"	0.082(#3) 0.082(#5)	1.05	0.33	0.38	0.1	36
1290-004-0039-01	3mm, 1 1-4, GCl-arg95-8071#3-arg95-8071#5, ms, SDL < 1"	0.082(#3) 0.082(#5)	1.05	0.37	0.42	0.1	38
1290-004-0040-01	3mm, 1 1-4, GCl-arg95-8071#3-arg95-8071#5, ms, SDL >= 1"	0.082(#3) 0.082(#5)	1.05	0.33	0.38	0.1	36
1290-004-0041-01	HP, 3mm, 7-8, GCl-arg95-8071#3, dl	0.082(#3)	1.52	0.47	0.52	0.1	34
1290-004-0042-01	HP, 3mm, 7-8, GCl-arg95-8071#3, dl, Grids < 1"	0.082(#3)	1.52	0.42	0.47	0.1	31
1290-004-0043-01	HP, 3mm, 7-8, GCl-arg95-8071#3, dl, Grids >= 1"	0.082(#3)	1.52	0.38	0.42	0.1	28
1290-004-0044-01	HP, 3mm, 7-8, GCl-arg95-8071#3, dl, SDL < 1"	0.082(#3)	1.52	0.42	0.47	0.1	31
1290-004-0045-01	HP, 3mm, 7-8, GCl-arg95-8071#3, dl, SDL >= 1"	0.082(#3)	1.52	0.38	0.42	0.1	28

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com