

# Notice of Product Certification

CERTIFICATION NO.: 1684-015  
INITIAL CERTIFICATION DATE: September 6, 2023  
REVISION DATE: N/A  
REPORT NUMBER: CAR234897.1215-f  
SPECIFICATION: CSA A440.2-19

COMPANY: Aluminium Caruso  
CODE: 1684-1  
EXPIRATION DATE: June 2, 2028  
PRODUCT SIMULATED BY: WSP  
AIR LEAKAGE REPORT NO.: AI-03681-C1

PRODUCT/SERIES NAME: S-4350 Double Hung OPERATOR TYPE: VSDH

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1684-015-0001-01	GCI-arg95-8071, im	0.082(#3)	1.62	0.52	0.58	0.5	34
1684-015-0001-02	GCI-arg95-8071, im, Grids<1 Inch	0.082(#3)	1.62	0.46	0.52	0.5	30
1684-015-0002-01	SDCL-arg95-8071, im	0.082(#3)	1.62	0.54	0.59	0.5	35
1684-015-0002-02	SDCL-arg95-8071, im, Grids<1 Inch	0.082(#3)	1.62	0.49	0.52	0.5	32
1684-015-0003-01	8071-arg95-GCI-arg95-8071, im	0.082(#2, #5)	1.34	0.43	0.52	0.5	35

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'Shirley'.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
nami@namiinc.com  
namicertification.com