

Notice of Product Certification

CERTIFICATION NO.: 839-008

INITIAL CERTIFICATION DATE: September 27, 2023

REVISION DATE: N/A

REPORT NUMBER: SPL22001-17-C_HSOX-P

SPECIFICATION: CSA A440.2-22

COMPANY: Profenex

CODE: 839-1

EXPIRATION DATE: November 18, 2027

PRODUCT SIMULATED BY: Veridis Solutions

AIR LEAKAGE REPORT NO.: AI-04110-E1 Rev.1

PRODUCT/SERIES NAME: Coulissant Simple PVC 9620-9820 **OPERATOR TYPE:** HSOX

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
839-008-0001-01	GL 3mm_7/8_PCl-arg95-8071 iu	0.082(#3)	1.61	0.53	0.59	0.4	35
839-008-0002-01	GL 3mm_7/8_PCl-arg95-8071 iu Grids<1"	0.082(#3)	1.61	0.47	0.52	0.4	31
839-008-0003-01	GL 3mm_7/8_PCl-arg95-8071 iu Grids>1"	0.082(#3)	1.61	0.42	0.46	0.4	28
839-008-0004-01	GL 3mm_7/8_STCl-arg95-SG400 iu	0.113(#3)	1.66	0.54	0.58	0.4	34
839-008-0005-01	GL 3mm_7/8_STCl-arg95-SG400 iu Grids<1"	0.113(#3)	1.66	0.48	0.52	0.4	31
839-008-0006-01	GL 3mm_7/8_STCl-arg95-SG400 iu Grids>1"	0.113(#3)	1.66	0.43	0.46	0.4	28
839-008-0007-01	GL 3mm_7/8_PCl-arg95-LOF su	0.164(#3)	1.69	0.56	0.56	0.4	35
839-008-0008-01	GL 3mm_7/8_PCl-arg95-LOF su Grids<1"	0.164(#3)	1.69	0.50	0.50	0.4	31
839-008-0009-01	GL 3mm_7/8_PCl-arg95-LOF su Grids>1"	0.164(#3)	1.69	0.44	0.44	0.4	28
839-008-0010-01	GL 3mm_7/8_PCl-arg95-8071 su	0.082(#3)	1.57	0.53	0.59	0.4	35
839-008-0011-01	GL 3mm_7/8_PCl-arg95-8071 su Grids<1"	0.082(#3)	1.57	0.47	0.52	0.4	32
839-008-0012-01	GL 3mm_7/8_PCl-arg95-8071 su Grids>1"	0.082(#3)	1.57	0.42	0.46	0.4	29
839-008-0013-01	GL 3mm_7/8_STCl-arg95-SG400 su	0.113(#3)	1.62	0.54	0.58	0.4	35
839-008-0014-01	GL 3mm_7/8_STCl-arg95-SG400 su Grids<1"	0.113(#3)	1.62	0.48	0.52	0.4	31
839-008-0015-01	GL 3mm_7/8_STCl-arg95-SG400 su Grids>1"	0.113(#3)	1.62	0.43	0.46	0.4	29
839-008-0016-01	BF 3mm_7/8_PCl-arg95-8071 iu	0.082(#3)	1.61	0.53	0.59	0.4	35
839-008-0017-01	BF 3mm_7/8_PCl-arg95-8071 iu Grids<1"	0.082(#3)	1.61	0.47	0.52	0.4	31
839-008-0018-01	BF 3mm_7/8_PCl-arg95-8071 iu Grids>1"	0.082(#3)	1.61	0.42	0.46	0.4	28
839-008-0019-01	BF 3mm_7/8_STCl-arg95-SG400 iu	0.113(#3)	1.66	0.54	0.58	0.4	34
839-008-0020-01	BF 3mm_7/8_STCl-arg95-SG400 iu Grids<1"	0.113(#3)	1.66	0.48	0.52	0.4	31
839-008-0021-01	BF 3mm_7/8_STCl-arg95-SG400 iu Grids>1"	0.113(#3)	1.66	0.43	0.46	0.4	28
839-008-0022-01	BF 3mm_7/8_PCl-arg95-LOF su	0.164(#3)	1.69	0.56	0.56	0.4	35
839-008-0023-01	BF 3mm_7/8_PCl-arg95-LOF su Grids<1"	0.164(#3)	1.69	0.50	0.50	0.4	31
839-008-0024-01	BF 3mm_7/8_PCl-arg95-LOF su Grids>1"	0.164(#3)	1.69	0.44	0.44	0.4	28
839-008-0025-01	BF 3mm_7/8_PCl-arg95-8071 su	0.082(#3)	1.57	0.53	0.59	0.4	35

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
839-008-0026-01	BF 3mm_7/8_PCl-arg95-8071 su Grids<1"	0.082(#3)	1.57	0.47	0.52	0.4	32
839-008-0027-01	BF 3mm_7/8_PCl-arg95-8071 su Grids>1"	0.082(#3)	1.57	0.42	0.46	0.4	29
839-008-0028-01	BF 3mm_7/8_STCl-arg95-SG400 su	0.113(#3)	1.62	0.54	0.58	0.4	35
839-008-0029-01	BF 3mm_7/8_STCl-arg95-SG400 su Grids<1"	0.113(#3)	1.62	0.48	0.52	0.4	31
839-008-0030-01	BF 3mm_7/8_STCl-arg95-SG400 su Grids>1"	0.113(#3)	1.62	0.43	0.46	0.4	29

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S.M.D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.
 4794 George Washington Memorial Hwy.
 Hayes, VA 23072
 Tel.: (804) 684-5124
 nami@namiinc.com
 namicertification.com