

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015782.08  
**DATE:** 09/22/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Linea Rossa  
**CODE:** 2749-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Linea Rossa, LLC</b> <b>1850 Northwest 84th Avenue, Suite 114</b> <b>Doral, FL 33126</b>	<b>Series "LRWAD-280"</b> <b>Aluminum Sliding Glass Door &amp;</b> <b>Lift &amp; Slide System</b>  Configuration: OXXO Glazing: IG - 1/4" Heat Strengthened Glass/1/4" Heat Strengthened Glass/0.060" Kuraray PVB Interlayer/1/4" Heat Strengthened Glass or Monolithic - 1/4" Heat Strengthened Glass/0.060" Kuraray PVB Interlayer/1/4" Heat Strengthened Glass or Monolithic - 1/4" Tempered Glass/0.060" Kuraray PVB Interlayer/1/4" Tempered Glass Frame: W-6220mm(244.88") H-3048mm(120") Panel: W-1562mm(61.5") H-2972mm(117") DLO: W-1414mm(55.69") H-2794mm(110")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3830 Pa (±80 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: QAI Laboratories  
Report No: 13309  
Expiration Date: April 30, 2027

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)