NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI015782.10

DATE: <u>09/22/2023</u>

CERTIFICATION PROGRAM: Structural

COMPANY: <u>Linea Rossa</u>

CODE: 2749-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---------------------------------------|---|
| Linea Rossa Windows and Doors | Series "LRWAD-280" |
| 1850 Northwest 84th Avenue, Suite 114 | Aluminum Sliding Glass Door & |
| Doral, FL 33126 | Lift & Slide System |
| | Configuration: OXXX |
| | Glazing: IG - 1/4" Heat Strengthened Glass/0.090" Kuraray PVB Interlayer/1/4" Heat Strengthened Glass |
| | IG - 1/4" Heat Strengthened Glass/1/4" Heat Strengthened Glass/0.090" Kuraray PVB Interlayer/1/4" Heat Strengthened Glass |
| | Frame: W-6085mm(239.56") H-3048mm(120") |
| | Panel: W-1562mm(61.50") H-2972mm(117") |
| | DLO: W-1414mm(55.69") H-2794mm(110") |

| SPECIFICATION | PRODUCT RATING |
|--------------------|---|
| TAS 201/202/203-94 | Design Pressure: ±3840 Pa (±80 psf) Large Missile Impact Rated |

Product Tested By: QAI Laboratories

Report No: 13308

Expiration Date: April 30, 2027

Administrator's Signature: ___

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023