

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015837.02  
**DATE:** 09/26/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Intus  
**CODE:** 1817-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Intus Windows, LLC</b> <b>2720 Prosperity Avenue, 400-1</b> <b>Fairfax, VA 22031</b>	<b>Series "Supera"</b> <b>Vinyl Hopper Window</b>  Configuration: X  Glazing: Insulating Glass (Annealed)  Frame: W-1499mm(59") H-1200mm(47.25") Vent: W-1422mm(56") H-1124mm(44.25") DLO: W-1270mm(50") H-972mm(38.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class CW-PG70 1499 x 1200 (59 x 47)-AP</b> <b>Design Pressure: ±3360 Pa (±70 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf)</b>

Product Tested By: Molimo Architectural Product Testing  
Report No: 12196.03-106-13/W-2081  
Expiration Date: **March 31, 2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)