

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015837.03
DATE: 09/26/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Intus
CODE: 1817-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Intus Windows, LLC 2720 Prosperity Avenue, 400-1 Fairfax, VA 22031	Series "Supera" Vinyl Hopper Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1499mm(59") H-1200mm(47.25") Vent: W-1422mm(56") H-1124mm(44.25") DLO: W-1270mm(50") H-972mm(38.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG70 1499 x 1200 (59 x 47)-AP Design Pressure: ±3360 Pa (±70 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf)

Product Tested By: Molimo Architectural Product Testing
Report No: 12196.03-106-13/W-2081
Expiration Date: **March 31, 2027**

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com