

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015839.01-R1
DATE: 08/03/2023
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView® Classic Single Hung Vinyl Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-902mm(35.50") H-1918mm(75.50") Sash: W-831mm(32.72") H-951mm(37.42") DLO: W-745mm(29.34") H-865mm(34.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG50 902 x 1918* (36 x 76*)-H Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)

Product Tested By: Intertek, PLC
Report No: P5942.04-550-44/P5942.01-550-44/W-2119
Expiration Date: **December 31, 2027**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.M.", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023